

GREATER WARANGAL MUNICIPAL CORPORATION

From
Sarfaraz Ahmed, I.A.S.,
Commissioner,
Greater Warangal Municipal Corporation
Warangal

To
The District Education Officer
Warangal District
Telangana

RC. No. HO/DFO/24611/GWMC/SCHOOL/2016. Dt. 16-07-2016

SUB:- Greater Warangal Municipal Corporation – Fire Prevention Wing – Issuance of Renewal of Fire No Objection Certificate for occupancy to the existing Non MSB of M/S Oasis Public School, H.No. 11-23-2357, Deshaipet Road, Warangal – Reg.

- REF:-
1. Application of the correspondent of Oasis Public School, H.No. 11-23-2357, Deshaipet Road, Warangal Dt. 14-07-2016.
 2. Rc. No. 5041/B2/97, Dt: 12-03-2010 of the Director General of State Disaster Response and Fire Services, A.P. Hyderabad.
 3. Inspection report of officers of Fire Prevention Wing, GWMC, Warangal Vide Rc. No. HO/FO/WMC/24611/2016. Dt.15-07-2016.

Vide ref. 3rd cited, the Officers of the Fire Prevention Wing, WMC, Warangal have inspected the premises of the M/S Oasis Public School, H.No. 11-23-2357, Deshaipet Road, Warangal Dt. 15-07-2016.

2. The Management has constructed the Multi Storied School Building with Ground + 2 Upper floors with a height of 9.25 mtrs for Educational occupancy (B) and submitted application for issuance of Renewal of Fire No Objection Certificate for occupancy to the above existing building.

3. Particulars of the Building:

- a) Address of the Building : M/S Oasis Public School, H.No. 11-23-2357, Deshaipet Road, Warangal, Telangana.
- b) Height of the Building : 9.25 mtrs
- c) No. of Blocks / Floors : One Block / Ground + 2 Upper Floors
- d) Type of Occupancy : Educational (B)
- e) Floor wise details : Given Below

Sl. No.	Floor	Area in Sq. Mtrs	Occupancy	Occupants load
1	Ground Floor	957.70	Educational (B2)	400
2	First Floor	924.13	Educational (B)	225
3	Second Floor	957.50	Educational (B)	225
	Total	2839.33 Sq. mtrs		

4. Means of Escape:-

The Management has provided 01 No. of staircases with a width of 1.50 mtrs and internal staircase with a width of 0.80 mtr Total width of 4.65 mtrs. The means of escape is satisfactory as per table 20 and 21 of Part – IV of NBC of India 2005.

5. The following Fire Safety measures are provided as per Table 23 of Part – IV of NBC of India 2005. The equipment tested during the inspection and found working satisfactorily:

Sl. No.	Fire Safety Measure	Required	Provided	Deficit
1.	Fire Buckets (Sand & Water)	04 Nos	04 Nos	Nil
2.	Fire Extinguishers (Water CO2, DCP-5 kgs and CO2 4.5 Kgs)	02 Nos	10 Nos	Nil
3.	Hose Reel	01 No	04 Nos	Nil
4.	Terrace Water Tank	10,000 Ltrs	10,000 Ltrs	Nil
5.	Booster Pump	450 LPM	450 LPM	Nil
6.	2 way Fire Service inlet	Not required	20,000 Ltrs	Nil

6. The above Fire Fighting System item wise randomly tested and found in good working condition.

In view of the above **Fire No Objection Certificate** for occupancy is issued for the Existing above School Building subject to the following conditions:

1. The NOC issued is confined to the Fire Safety measures installed in the Building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularisation, The Owner / Occupier shall comply the Building Rules / Govt. Orders as applicable.
2. Evacuation plan showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited at all times, all escape/exit routes shall not be blocked or encroached.
3. Fresh NOC would be required for any change in occupancy as per NBC and building bye/laws.
4. The Management has to maintain Fire Safety Measures at all times in good working condition as seen during the inspection.
5. Any Loss of fire or property due to Non – functioning of Fire Safety Measures and other installations shall be the responsibility of the Management/owner.
6. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
7. All Occupants/Security personnel shall be trained to operate the Fire Safety Equipment during emergency.
8. A Fire Drill shall be conducted once in every six months.

The Management has remitted Fire Precautionary fees vide challan No. 26308 Dt. 15-07-2016 for Rs. 10,000/- at SBH, Treasury Branch, Hanamkonda.

[Signature]
Commissioner,
GWMC – Warangal.

Copy to:

1. Correspondent, M/S Oasis Public School, H.No. 11-23-2357, Deshaipet Road, Warangal.
2. Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.